

Electrical Load Schedule

Scenario: Live Database (Current Status)

Date Generated: 6/17/2026, 5:19:29 PM

SWGR R11					4160.00V
Equipment	Type	Status	Rating	Power Apparent	
P1001	MOTOR	RUNNING	500.00 HP	477.0 kVA	
▼ Sub-Feed: R11A	Bus Feeder	ENERGIZED	--	824.9 kVA	
▼ Sub-Feed: R11B	Bus Feeder	ENERGIZED	--	190.8 kVA	
Net Demand: 1492.1 kVA				Current: 207.1 A	

R11A					480.00V
Equipment	Type	Status	Rating	Power Apparent	
AC 301A	STATIC	RUNNING	200.00 kW	222.2 kVA	
AC 301B	STATIC	RUNNING	200.00 kW	222.2 kVA	
P401A	MOTOR	RUNNING	50.00 HP	47.7 kVA	
P401B	MOTOR	RUNNING	50.00 HP	47.7 kVA	
P401C	MOTOR	RUNNING	50.00 HP	47.7 kVA	
P401D	MOTOR	RUNNING	50.00 HP	47.7 kVA	
P403E	MOTOR	RUNNING	50.00 HP	47.7 kVA	
P403F	MOTOR	RUNNING	50.00 HP	47.7 kVA	
P403G	MOTOR	RUNNING	50.00 HP	47.7 kVA	
P403H	MOTOR	RUNNING	50.00 HP	47.7 kVA	
Net Demand: 824.9 kVA				Current: 992.2 A	

R11B

480.00V

Equipment	Type	Status	Rating	Power Apparent
P405A	MOTOR	RUNNING	50.00 HP	47.7 kVA
P405B	MOTOR	RUNNING	50.00 HP	47.7 kVA
P405C	MOTOR	RUNNING	50.00 HP	47.7 kVA
P405D	MOTOR	RUNNING	50.00 HP	47.7 kVA
Net Demand: 190.8 kVA				Current: 229.5 A